



Fair
Trading

Ref: CS11078/1

ADDENDUM TO CERTIFICATE OF SUITABILITY: CS11078N Particulars of Modification(s)

Model GW60KN-MT being similar to original model GW80K-MT except that Input DC current:33/33/33/33A; Isc PV: 41.5/41.5/41.5/41.5Ad.c; Nominal output AC current: 86.6A; Max output AC current: 96A; Nominal output power: 60kW; Max apparent output power: 66kVA.

Model GW50KN-MT being similar to original model GW80K-MT except that Input DC current:33/33/22/22A; Isc PV: 41.5/41.5/27.5/27.5Ad.c; Nominal output AC current: 72.2A; Max output AC current: 80A; Nominal output power: 50kW; Max apparent output power: 55kVA.

This certificate will expire on 03/05/2027

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:
3 May 2022

9 May 2022

For Secretary, Department of Customer Service